



COMMONWEALTH of VIRGINIA

Doug Domenech
Secretary of Natural Resources

DEPARTMENT OF ENVIRONMENTAL QUALITY
TIDEWATER REGIONAL OFFICE
5636 Southern Boulevard, Virginia Beach, Virginia 23462
(757) 518-2000 Fax (757) 518-2009
www.deq.virginia.gov

David K. Paylor
Director

Maria R. Nold
Regional Director

July 25, 2012

CERTIFIED MAIL
RETURN RECEIPT REQUESTED

Mr. Edward G. Henifin
General Manager
Hampton Roads Sanitation District
1436 Air Rail Ave
Virginia Beach, VA 23455

RE: VPDES Permit No. VA0081230
Reissuance for HRSD-Army Base STP
Norfolk, VA

Dear Mr. Henifin:

The enclosed effluent limitations and monitoring requirements for the above referenced permit have been approved. Additionally, enclosed are copies of the fact sheet pages that describe public participation in the permitting process. Please replace the pages in fact sheet that you received with the draft permit with these pages.

Your permit is also enclosed. In accordance with the permit, you are required to submit monitoring reports to the following address:

Department of Environmental Quality (DEQ)
Tidewater Regional Office
5636 Southern Boulevard
Virginia Beach, VA 23462

The reporting forms are included with the permit. You will be responsible for obtaining additional copies of the reporting forms. The first report (DMR) is due for the month of February 2013 by March 10, 2013.

Please note that compliance with the permit's requirements for use and disposal of sewage sludge does not relieve you of your responsibility to comply with federal requirements set forth in 40 CFR Part 503. Until DEQ seeks and is granted authority to administer the Part 503 regulations by EPA, treatment works treating domestic sewage should continue to work directly with EPA to comply with them. For more information, you can call the EPA Region III office in Philadelphia at 215-814-5735.

As provided by Rule 2A:2 of the Supreme Court of Virginia, you have thirty days from the date of service (the date you actually received this decision or the date it was mailed to you, whichever occurred first) within which to appeal this decision by filing a notice of appeal in accordance with the Rules of the Supreme Court

of Virginia with the Director, Department of Environmental Quality. In the event that this decision is served on you by mail, three days are added to that period.

Alternatively, any owner under Section 62.1-44.16, 62.1-44.17, and 62.1-44.19 of the State Water Control Law aggrieved by any action of the State Water Control Board taken without a formal hearing, or by inaction of the Board, may demand in writing a formal hearing of such owner's grievance, provided a petition requesting such hearing is filed with the Board. Said petition must meet the requirements set forth in Section 1.23(b) of the Board's Procedural Rule No. 1. In cases involving actions of the Board, such petition must be filed within thirty days after notice of such action is mailed to such owner by certified mail.

A Reliability Class I is assigned to this facility and this facility has Class I licensed wastewater operator requirements.

DEQ has launched an e-DMR program that allows you to submit the effluent data electronically. We anticipate that in the near future all permittees will be participants in the e-DMR program. There are many benefits to both DEQ and the permittee when e-DMR is utilized for submissions:


- 1) Fewer revisions for data since the e-DMR program automatically flags omissions before the data is submitted;
- 2) Cost savings on postage, copying, and paper;
- 3) No concerns about using the most current DMR – e-DMR refreshes the required parameters automatically when changes are needed;
- 4) Submittals can be made on a timelier basis; and
- 5) Electronic signatures from multiple people are allowed and e-DMR can be accessed from multiple computer locations.

We ask that you apply for e-DMR participation now so that we will be able to complete the application process when your permit is effective. The following website provides details and our regional e-DMR administrator Debbie Kay, phone 757-518-2127, Deborah.kay@deq.virginia.gov can also assist you:

<http://www.deq.virginia.gov/water/edmrfaq.html>

If you have any additional questions, please do not hesitate to contact Deanna Austin at 757-518-2008 or deanna.austin@deq.virginia.gov

Sincerely,



Mark H. Sauer
Water Permit Manager

MHS/ DDA

cc: DEQ - TRO File ECM
EPA - Region III (3WP12)

Encl: Permit No. VA0081230
Revised Fact Sheet Pages

24. **RECEIVING WATERS INFORMATION:** Refer to the State Water Control Board's Water Quality Standards [e.g., River Basin Section Tables (9 VAC 25-260-5 et seq.)]. Use 9 VAC 25-260-140 C (introduction and numbered paragraph) to address tidal waters where fresh water standards would be applied or transitional waters where the most stringent of fresh or salt water standards would be applied. Attach any memoranda or other information which helped to develop permit conditions (i.e. tier determinations, PReP complaints, special water quality studies, STORET data and other biological and/or chemical data, etc.

SEE ATTACHMENT 9

25. **305(b)/303(d) Listed Segments:** Indicate if the facility discharges to a segment that is listed on the current 303(d) list and, if so, provide all appropriate information/calculations.

This facility discharges directly to the Elizabeth River. This receiving stream segment has been listed in Category 5 of the 305(b)/303(d) list for non-attainment of DO, estuarine benthics, and PCBs.

EPA approved the Chesapeake Bay TMDL on 12/29/10 for this segment. This is for nitrogen, phosphorus, and TSS. The facility is listed in the TMDL as a non-significant discharger. Because an aggregated WLA exists, this permit did not receive an individual WLA.

A PCB TMDL for the tidal James River and Elizabeth River has an anticipated completion date of 2014.

26. **CHANGES TO PERMIT:** Use **TABLE III(a)** to record any changes from the previous permit and the rationale for those changes. Use **TABLE III(b)** to record any changes made to the permit during the permit processing period and the rationale for those changes [i.e., use for comments from the applicant, VDH, EPA, other agencies and/or the public where comments resulted in changes to the permit limitations or any other changes associated with the special conditions or reporting requirements].

SEE ATTACHMENT 10

27. **NPDES INDUSTRIAL PERMIT RATING WORKSHEET:**

N/A - This is a municipal facility.

28. **DEQ PLANNING COMMENTS RECEIVED ON DRAFT PERMIT:** Document any comments received from DEQ planning.

The discharge is addressed in the Virginia Water Quality Management Plan (VAC25-720-60C). Limits for TN and TP are in the plan. TN and TP limits are met under the Nutrient GP bubble permit for the James River (VAN040090).

29. **PUBLIC PARTICIPATION:** Document comments/responses received during the public participation process. If comments/responses provided, especially if they result in changes to the permit, place in the attachment.

VDH/DSS COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from the Virginia Dept. of Health and the Div. of Shellfish Sanitation and noted how resolved.

The VDH reviewed the application and waived their right to comment and/or object on the adequacy of the draft permit. Memo received 6/5/12.

The DSS has no comments on the application/draft permit. Memo received 7/20/12.

EPA COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from the U.S. Environmental Protection Agency and noted how resolved.

EPA has no objections to the adequacy of the draft permit. Email received 7/13/12.

ADJACENT STATE COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from an adjacent state and noted how resolved.

Not Applicable.

OTHER AGENCY COMMENTS RECEIVED ON DRAFT PERMIT: Document any comments received from any other agencies (e.g., VIMS, VMRC, DGIF, etc.) and noted how resolved.

Not Applicable.

OTHER COMMENTS RECEIVED FROM RIPARIAN OWNERS/CITIZENS ON DRAFT PERMIT: Document any comments received from other sources and note how resolved.

The application and draft permit have received public notice in accordance with the VPDES Permit Regulation, and no comments were received.

DESCRIBE PN COMMENTS AND RESOLUTIONS. PROVIDE PUBLIC HEARING DATE AND REFERENCE BACKGROUND MEMORANDUM, IF APPROPRIATE.

PUBLIC NOTICE INFORMATION: Comment Period: Start Date 6/20/12
End Date 7/20/12

Persons may comment in writing or by e-mail to the DEQ on the proposed issuance/reissuance/modification of the permit within 30 days from the date of the first notice. Address all comments to the contact person listed below. Written or e-mail comments shall include the name, address, and telephone number of the writer, and shall contain a complete, concise statement of the factual basis for comments. Only those comments received within this period will be considered. The Director of the DEQ may decide to hold a public hearing if public response is significant. Requests for public hearings shall state the reason why a hearing is requested, the nature of the issues proposed to be raised in the public hearing and a brief explanation of how the requestor's interests would be directly and adversely affected by the proposed permit action.

All pertinent information is on file and may be inspected, and arrangements made for copying by contacting Deanna Austin at: Department of Environmental Quality (DEQ), Tidewater Regional Office, 5636 Southern Boulevard, Virginia Beach, VA 23462. Telephone: 757-518-2008 E-mail: deanna.austin@deq.virginia.gov

Following the comment period, the Board will make a determination regarding the proposed issuance/reissuance/modification. This determination will become effective, unless the Director grants a public hearing. Due notice of any public hearing will be given.

30. **ADDITIONAL FACT SHEET COMMENTS/PERTINENT INFORMATION:**